



8820 Old Hwy 99 SE, Tumwater, Washington 98501, USA  
360-943-6063 800-562-6184 FAX 360-352-4813 www.ch2o.com



# 6300

## Non-Phosphorous Cooling Tower Treatment

### APPLICATION

Mineral crystallization on cooling system heat-transfer surfaces is the chief cause for cooling system failure. Loss of heat conduction causes loss of cooling efficiency and may cause excessive energy consumption. If mineral deposits are formed, high compressor pressures or temperatures will cause the refrigeration equipment to consume higher electrical energy. Also, process cooling units lose ability to transfer heat. In either case, loss of efficiency can lead to a complete system shutdown.

**6300** is an aqueous blend of polymers and corrosion inhibitors. The product is moderately stable in the presence of oxidizing biocides.

**6300** is formulated to meet cooling tower needs where discharge of phosphates and phosphorous has been prohibited.

### SAFETY & HANDLING PROCEDURE

This product is a highly acidic liquid. It can be handled safely using the standard precautionary procedures associated with industrial chemicals of this type. Read and understand the MSDS before handling this product.

### FEEDING TECHNIQUE

Inject through a chemical pump, add to an area of high dispersion to avoid direct contact of the concentrated product with system metal.

### CONTROL

Product residual is monitored with an electronic COLORIMETER, Model #942. It is recommended that the system water be maintained to yield a reading of 0.07-0.14 on the meter at all times.

Daily testing is recommended to maintain proper control. Failure to monitor and maintain treatment levels can cause damage. In addition to monitoring and maintaining treatment levels, it is the customer's responsibility to ensure the product is fit for its intended application. Contact your CH<sub>2</sub>O water treatment specialist for further information on analytical testing.

### DOSAGE

Initially charge the system at the rate of 18 fluid ounces per 1,000 gallons of system capacity. Maintain system treatment by feeding **6300** at a rate proportionate to the cycles of concentration being maintained with respect to the volume of feed water.

### PHYSICAL PROPERTIES

pH of 1% Solution.....	2-4
Pounds per Gallon.....	10-10.5
Physical Appearance.....	Clear, Colorless Liquid
Odor.....	Mild
Flash Point.....	NA

### Seller Warranty

CH<sub>2</sub>O brand test reagent refills are available through your sales representative at no charge. Customers are required to confirm product compatibility via a control test for their specific application. CH<sub>2</sub>O recommends that you perform regular/daily testing to control chemical levels and cycles of concentration within established limits. Additional tests may be performed at your request. Test reports reflect conditions at the point when the analysis was performed. Results will change over time and with varying operating conditions.

Seller warrants that this product conforms to its chemical description and is reasonably fit for the purpose referred to in the product data sheet. Buyer is responsible to ensure that products and product dosages are appropriate for Buyer's particular application. Seller makes no other warranty or representation of any kind, express or implied, concerning the product, including NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS OF THE GOODS FOR ANY OTHER PARTICULAR PURPOSE. No such warranties shall be implied by law and no agent of seller is authorized to alter this warranty in any way except in writing with a specific reference to this warranty. The exclusive remedy against seller shall be a claim for damages not to exceed the purchase price of the product, without regard to whether such a claim is based upon breach of warranty or tort. Jurisdiction for any issues arising from or relating to this product shall be in the courts of the State of Washington and the venue shall be Thurston County. Any controversy or claim arising out of or relating to this contract, or breach thereof, shall be settled by arbitration in accordance with the rules and procedures as stated in RCW 7.06 and shall be binding upon both parties without right to appeal, and judgment upon the award rendered by the Arbitrator(s) may be entered in any court having jurisdiction thereof.

Applies to all products sold by CH<sub>2</sub>O, Inc., and is hereby communicated to all of its customers as a condition of sale. Use of CH<sub>2</sub>O products is subject to the Standard Terms and Conditions as listed on CH<sub>2</sub>O, Inc.'s website at: [www.ch2o.com](http://www.ch2o.com).



VERSION DATE: May 26, 2009 | REVISION DATE: February 22, 2019

