

SEA FRESH SYSTEM



OPERATIONAL CONSIDERATIONS

Currently standard inlet and outlet pipe size for this Unit is 1" schedule 80 PVC piping. Other pipe sizing needs to be requested.

TESTING REQUIREMENTS

Chemical residual should be tested routinely with CH₂O, Inc. Total Oxidant (TEI-1) test kit to ensure desired product feed is maintained.

A control test is necessary on each water system; customers shall set treatment levels based on their control test results.

PREVENTATIVE MAINTENANCE (PM)

Pumps	Yearly replacement kit
Sock Filter	Replaced, as needed

INDUSTRIES

Residential Potable Water	Commercial Potable Water
Livestock	

TYPICAL APPLICATIONS

Residential Water Treatment	Commercial Water Treatment
Livestock Watering Systems	

PRODUCT

Sea Fresh (NSF 60 registered as potable water treatment)

HISTORY

Sea Fresh is a single drum chemical feed system for potable water that can control odor and minimize scaling due to problem water sources.

The system is easy to install and requires minimal maintenance. The equipment utilizes a proportional feed control, where feed rate of chemical is determined by water flow rate. More information is available at www.ch2o.com.



Does your water smell?

Are Iron stains discoloring everything in your home?

Have you stopped drinking your own water?

Discover a solution to your problems that will save you money.

Introducing a NEW potable water treatment technology that will provide results – fast and easy!

A safe and proven solution is just a water analysis away!

Seller Warranty

CH₂O brand test reagent refills are available through your sales representative at no charge. Customers are required to confirm product compatibility via a control test for their specific application. CH₂O recommends that you perform regular/daily testing to control chemical levels and cycles of concentration within established limits. Additional tests may be performed at your request. Test reports reflect conditions at the point when the analysis was performed. Results will change over time and with varying operating conditions.

Seller warrants that this product conforms to its chemical description and is reasonably fit for the purpose referred to in the directions for use when used in accordance with the directions under normal conditions. Buyer assumes the risk of any use contrary to such directions. Seller makes no other warranty or representation of any kind, express or implied, concerning the product, including NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS OF THE GOODS FOR ANY OTHER PARTICULAR PURPOSE. No such warranties shall be implied by law and no agent of seller is authorized to alter this warranty in any way except in writing with a specific reference to this warranty. The exclusive remedy against seller shall be a claim for damages not to exceed the purchase price of the product, without regard to whether such a claim is based upon breach of warranty or tort. Jurisdiction for any issues arising from or relating to this product shall be in the courts of the State of Washington and the venue shall be Thurston County. Any controversy or claim arising out of or relating to this contract, or breach thereof, shall be settled by arbitration in accordance with the rules and procedures as stated in RCW 7.06 and shall be binding upon both parties without right to appeal, and judgment upon the award rendered by the Arbitrator(s) may be entered in any court having jurisdiction thereof.

Applies to all products sold by CH₂O, Inc., and is hereby communicated to all of its customers as a condition of sale. Use of CH₂O products is subject to the Standard Terms and Conditions as listed on CH₂O, Inc.'s website at: www.ch2o.com.