



8820 Old Hwy 99 SE, Tumwater, Washington 98501, USA
360-943-6063 8000-562-6184 FAX 360-352-4813 www.ch2o.com



6147U SYNTHETIC ORGANIC DISPERSANT

APPLICATION

Solid materials are frequently present in boiler, hydronic loop, and processing water in the form of suspended particles. They may also be located in deposits within equipment where water circulates. Many processes cause suspended solids to be created by reaction of soluble materials during water utilization. Deposits and accumulations of these materials on heat-transfer surfaces cause operating energy losses. Boilers and hydronic loops are typical of heat-transfer processes that are affected. In the case of process circulation water, deposits promote "under deposit corrosion" which can rapidly destroy valuable equipment.

Mineral deposits can be mobilized and removed from operating equipment by a variety of effective organic dispersants. Synthetic organic dispersants have been developed to provide results that are superior to natural products used in the early history of water treatment. The varieties available include general-purpose dispersants and some dispersants that are particularly effective on specific substances.

Product **6147U** is used alone for cleaning newly installed equipment or as a supplement in water treatment programs for USDA applications. Product **6147U** is a blend of dispersants to give a broad range of effectiveness and exceptional results for minerals found in boilers and hydronic loops.

SAFETY & HANDLING PROCEDURE

This product is a neutral liquid. It can be safely handled using the standard precautionary measures associated with industrial chemicals. Avoid prolonged or repeated skin contact.

FEEDING TECHNIQUE

Inject directly into the feedwater line, makeup water line, or boiler. For cleaning operations, addition can be made with a bypass feeder or one-shot feeder.

CONTROL

The chemical residual depends upon the application requirements. Typical applications use 10 ppm. Consult your CH₂O water treatment specialist for individual recommendation. Daily testing is recommended to maintain proper control. Failure to monitor and maintain treatment levels can cause damage. In addition to monitoring and maintaining treatment levels, it is the customer's responsibility to ensure the product is fit for its intended application.

DOSAGE

Typical use requires 23.7 fluid ounces per 1,000 gallons. Feed rate will be reduced in boilers and cooling towers corresponding to the cycles of concentration. The dosage varies depending upon the amount and type of substance being dispersed.

PHYSICAL PROPERTIES

pH of 1% Solution	5.5 – 7.0
Pounds per Gallon	8.4 – 8.8
Physical Appearance	Clear Lt Tan Liquid
Odor	None
Flash Point	N/A

Seller Warranty

CH₂O brand test reagent refills are available through your sales representative at no charge. Customers are required to confirm product compatibility via a control test for their specific application. CH₂O recommends that you perform regular/daily testing to control chemical levels and cycles of concentration within established limits. Additional tests may be performed at your request. Test reports reflect conditions at the point when the analysis was performed. Results will change over time and with varying operating conditions.

Seller warrants that this product conforms to its chemical description and is reasonably fit for the purpose referred to in the product data sheet. Buyer is responsible to ensure that products and product dosages are appropriate for Buyer's particular application. Seller makes no other warranty or representation of any kind, express or implied, concerning the product, including NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS OF THE GOODS FOR ANY OTHER PARTICULAR PURPOSE. No such warranties shall be implied by law and no agent of seller is authorized to alter this warranty in any way except in writing with a specific reference to this warranty. The exclusive remedy against seller shall be a claim for damages not to exceed the purchase price of the product, without regard to whether such a claim is based upon breach of warranty or tort. Jurisdiction for any issues arising from or relating to this product shall be in the courts of the State of Washington and the venue shall be Thurston County. Any controversy or claim arising out of or relating to this contract, or breach thereof, shall be settled by arbitration in accordance with the rules and procedures as stated in RCW 7.06 and shall be binding upon both parties without right to appeal, and judgment upon the award rendered by the Arbitrator(s) may be entered in any court having jurisdiction thereof.

Applies to all products sold by CH₂O, Inc., and is hereby communicated to all of its customers as a condition of sale. Use of CH₂O products is subject to the Standard Terms and Conditions as listed on CH₂O, Inc.'s website at: www.ch2o.com.

